

System	Level	Location	MSSB	Equip. No.	Equipment Description	On General Fire Alarm		Smoke Clearance Mode		New System Flag	Level No.
						Required Action	Observed Action	Required Action	Observed Action		
AHU-1-1	LG2	PR 1	MSSB-1	AHU-1-1	Supply Air Fan	STOP		RUN		1	1
				RAF-1-1	Return Air Fan	STOP		RUN		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
					Return Air Damper	CLOSE		CLOSE		0	1
					Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	1
AHU-1-2	LG2	PR 1	MSSB-1		Relief Air Damper	CLOSE		OPEN		0	1
				AHU-1-2	Supply Air Fan	STOP		RUN		1	1
				RAF-1-2	Return Air Fan	STOP		RUN		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
					Return Air Damper	CLOSE		CLOSE		0	1
AHU-1-5	LG2	PR 1	MSSB-1		Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	1
					Relief Air Damper	CLOSE		OPEN		0	1
				AHU-1-5	Supply Air Fan	STOP		RUN		1	1
				RAF-1-5	Return Air Fan	STOP		RUN		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
AHU-15-1	LG2	PR 15	MSSB-15		Return Air Damper	CLOSE		CLOSE		0	1
					Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	1
					Relief Air Damper	CLOSE		OPEN		0	1
				AHU-15-1	Supply Air Fan	STOP		RUN		1	1
					Dehumidifier Outside Air Damper	STOP		STOP		0	1
AHU-1-6	LG2	PR 1	MSSB-1		Dehumidifier	STOP		STOP		0	1
				AHU-1-6	Supply Air Fan	STOP		RUN		1	1
				RAF-1-6	Return Air Fan	STOP		RUN		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
					Return Air Damper	CLOSE		CLOSE		0	1
AHU-1-7	LG2	PR 1	MSSB-1		Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	1
					Relief Air Damper	CLOSE		OPEN		0	1
				AHU-1-7	Supply Air Fan	STOP		RUN		1	1
				RAF-1-7	Return Air Fan	STOP		RUN		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
AHU-2-1	LG2	PR 2	PR2 LG2 WEST		Return Air Damper	CLOSE		CLOSE		0	1
					Relief Air Damper	CLOSE		OPEN		0	1
					Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	1
					Relief Air Damper	CLOSE		CLOSE		0	1
				AHU-2-1	Supply Air Fan	STOP		RUN		1	1
AHU-3-1	LG2	PR 3	MSSB-3		Return Air Fan	STOP		STOP		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
					Return Air Damper	CLOSE		CLOSE		0	1
					Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	1
					Relief Air Damper	CLOSE		CLOSE		0	1
AHU-3-2	LG2	PR 3	MSSB-3	AHU-3-2	Supply Air Fan	STOP		RUN		1	1
				RAF-3-2	Return Air Fan	STOP		STOP		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
					Return Air Damper	CLOSE		CLOSE		0	1
					Dehumidifier Outside Air Damper	STOP		STOP		0	1
AHU-3-3	LG2	PR 3	MSSB-3		Dehumidifier	STOP		STOP		0	1
				AHU-3-3	Supply Air Fan	STOP		RUN		1	1
				RAF-3-3	Return Air Fan	STOP		STOP		0	1
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	1
					Return Air Damper	CLOSE		CLOSE		0	1
FCU-LG2-8 & 9	LG2	Plant Room 1	MSSB-1	OAF-LG2-01	Outside Air Fan	STOP		STOP		1	1
UPS Room Supply Air Fan	LG2	Plant Room 1	MSSB-1	SF 1-2	Supply Air Fan	STOP		STOP		1	1
Mailroom FCU	LG2	Plant Room 1	MSSB-1	FCU-LG2-8	FCU Supply Air Fan	STOP		STOP		1	1
Security Room FCU	LG2	Plant Room 1	MSSB-1	FCU-LG2-9	FCU Supply Air Fan	STOP		STOP		1	1
Boiler OAF	LG2	Plant Room 1	MSSB-1	OAF-HWB	Outside Air Fan	STOP		STOP		1	1
Battery Rm Exhaust	LG2	Corridor LG2.34	MSSB-1	EHF 1-1	Extract Fan	STOP		STOP		1	1
GF Gallery O/A FCU 2	LG2	Mezzanine Loading	MSSB-1	FCU-OA02	Fan Coil Unit	STOP		STOP		1	1
GF Gallery O/A FCU 1	LG2	Mezzanine Loading	MSSB-1	FCU-OA01	Fan Coil Unit	STOP		STOP		1	1
LG1 & LG2 North Smoke Exhaust Fan	LG2	Plant Room 3	MSSB-3	SEF-38	Smoke Exhaust Fan	STOP		RUN		1	1
LG1 & LG2 Smoke Exhaust Fan	LG2	Plant Room 3	MSSB-3	SEF-37	Smoke Exhaust Fan	STOP		RUN		1	1
PR 2 General Fan	LG2	Plant Room 2	PR2 LG2 WEST	PRF-32	General Fan	STOP		STOP		1	1
PR 3 General Fan	LG2	Plant Room 3	MSSB-3	PRF-34	General Fan	STOP		STOP		1	1
Boiler 1	LG2	Plant Room 1	MSSB-1	HWB-1	Boiler	STOP		STOP		1	1
Boiler 2	LG2	Plant Room 1	MSSB-1	HWB-2	Boiler	STOP		STOP		1	1
Boiler 3	LG2	Plant Room 1	MSSB-1	HWB-3	Boiler	STOP		STOP		1	1

LOWER GROUND 2

System	Level	Location	MSSB	Equip. No.	Equipment Description	On General Fire Alarm		Smoke Clearance Mode		New System Flag	Level No.
						Required Action	Observed Action	Required Action	Observed Action		
Smoke Curtain	LG1	Lift 3	DB8 - E	SC-LG1	Smoke Curtain	RELEASE		RELEASE		1	1
				SC-G	Smoke Curtain	RELEASE		RELEASE		0	1
				SC-1	Smoke Curtain	RELEASE		RELEASE		0	1
				SC-2	Smoke Curtain	RELEASE		RELEASE		0	1
				SC-3	Smoke Curtain	RELEASE		RELEASE		0	1
				SC-4	Smoke Curtain	RELEASE		RELEASE		0	1
AHU-4-1	LG1	PR 4	MCP-LG1-P4-1	AHU-4-1	Supply Air Fan	STOP		STOP		1	2
				RAF-4-1	Return Air Fan	STOP		STOP		0	2
					Economy Cycle Outside Air Damper	CLOSE		CLOSE		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		CLOSE		0	2
					Relief Air Damper	CLOSE		CLOSE		0	2
AHU-4-2	LG1	PR 4	MCP-LG1-P4-1	AHU-4-2	Supply Air Fan	STOP		STOP		1	2
				RAF-4-2	Return Air Fan	STOP		STOP		0	2
					Economy Cycle Outside Air Damper	CLOSE		CLOSE		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		CLOSE		0	2
					Relief Air Damper	CLOSE		CLOSE		0	2
AHU-4-3	LG1	PR 4	MCP-LG1-P4-2	AHU-4-3	Supply Air Fan	STOP		STOP		1	2
				RAF-4-3	Return Air Fan	STOP		STOP		0	2
					Economy Cycle Outside Air Damper	CLOSE		CLOSE		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		CLOSE		0	2
					Relief Air Damper	CLOSE		CLOSE		0	2
AHU-4-4	LG1	PR 4	MCP-LG1-P4-3	AHU-4-4	Supply Air Fan	STOP		STOP		1	2
				RAF-4-4	Return Air Fan	STOP		STOP		0	2
					Economy Cycle Outside Air Damper	CLOSE		CLOSE		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		CLOSE		0	2
					Relief Air Damper	CLOSE		CLOSE		0	2
AHU-4-5	LG1	PR 4A	MSSB 4A	AHU-4-5	Supply Air Fan	STOP		STOP		1	2
					Dehumidifier Outside Air Damper	CLOSE		CLOSE		0	2
					Dehumidifier	STOP		STOP		0	2
AHU-4-6	LG1	PR 4	MSSB-4	AHU-4-6	Supply Air Fan	STOP		STOP		1	2
				RAF-4-6	Return Air Fan	STOP		STOP		0	2
					Dehumidifier Outside Air Damper	CLOSE		CLOSE		0	2
					Dehumidifier	STOP		STOP		0	2
AHU-4-7	LG1	PR 4	MSSB 4A	AHU-4-7	Supply Air Fan	STOP		STOP		1	2
					Economy Cycle Outside Air Damper	CLOSE		CLOSE		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		CLOSE		0	2
AHU-5-1	LG1	PR 5	MSB1-LG2	AHU-5-1	Supply Air Fan	STOP		RUN		1	2
				RAF-5-1	Return Air Fan	STOP		STOP		0	2
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	2
					Relief Air Damper	CLOSE		CLOSE		0	2
AHU-6-1	LG1	PR 6	PR6 AHU 6/1	AHU-6-1	Supply Air Fan	STOP		RUN		1	2
				RAF-6-1	Return Air Fan	STOP		STOP		0	2
					Economy Cycle Outside Air Damper	CLOSE		OPEN		0	2
					Return Air Damper	CLOSE		CLOSE		0	2
					Minimum Outside Air Damper/ VAV box	CLOSE		OPEN		0	2
					Relief Air Damper	CLOSE		CLOSE		0	2
Bio Box Air Handling Unit	LG1	Bio Box	(TBC)	ACU-LG1-9	Air Handling Unit	STOP		STOP		1	2
FCU-LG1-1	LG1	Oral History	MCP-5	FCU-LG1-1	FCU Supply Air Fan	STOP		STOP		1	2
FCU-LG1-2	LG1	Oral History	MCP-5	FCU-LG1-2	FCU Supply Air Fan	STOP		STOP		1	2
FCU-LG1-3	LG1	Paperplate Café	MCP-5	FCU-LG1-3	FCU Supply Air Fan	STOP		STOP		1	2
FCU-LG1-4	LG1	Maps	MCP-5	FCU-LG1-4	FCU Supply Air Fan	STOP		STOP		1	2
FCU-LG1-9	LG1	Paperplate Café	MCP-5	FCU-LG1-9	FCU Supply Air Fan	STOP		STOP		1	2
FCU-LG1-10	LG1	Office Audio Visual	MSSB-4A	FCU-LG1-10	FCU Supply Air Fan	STOP		STOP		1	2
FCU-LG-M4	LG1	Paperplate Café	MCP-5	FCU-LG-M4	FCU Supply Air Fan	STOP		STOP		1	2
LG1 West Stacks Smoke Exhaust	LG1	External	PR 5 DB	SEF 35	Smoke Exhaust Fan	STOP		RUN		1	2
LG2 West Stacks Smoke Exhaust	LG1	External	PR2 LG2 WEST	SEF 36	Smoke Exhaust Fan	STOP		RUN		1	2
OAF-LG1-9	LG1	Paperplate Café	MCP-5	OAF-LG1-9	Outside Air Fan	STOP		STOP		1	2
Paper Plate Kitchen Exhaust	LG1	Corridor LG1.01	MSSB-1	GEF-LG1-2	Kitchen Exhaust	STOP		STOP		1	2
PR 6 General Fan	LG1	Plant Room 6	PR6 AHU 6/1	PRF-33	General Fan	STOP		STOP		1	2